

**State College Area School District
Office of Physical Plant
Ed Poprik, Director**

To: Board of School Directors
From: Ed Poprik
RE: **Change Order, Radio Park Asbestos Project**
Date: August 26, 2013

Recommend that the Board of School Directors approve General Contractor Change Order #1 at the Radio Park Asbestos Project, in an amount not to exceed \$1,700.78, to Penn Installations.

Background- This change is to add conduit to support wiring that had been supported by an asbestos ceiling, which was removed as part of this project. The wiring and lack of conduit was concealed by the existing ceiling and therefore an unforeseen condition.

This change falls within the project contingency and does not add scope to the project.